




U5240-O-100S




Catalog Number	U5240-O-100S
Marketing Product Description	4 Terminal Ring Type Plain Top 1-100 Ampere Main Breaker Single Pedestal Direct Bury Series Wired
UPC	784572287709
Length (IN)	10.25
Width (IN)	9.688
Height (IN)	80
Brand Name	Milbank
Type	Ring Type Meter Socket
Special Features	Florida Meter Group
Application	Mobile Home Power
Standard	UL Listed;Type 3R
Voltage Rating	Up to 240 Volts Alternating Current
Amperage Rating	200 Continuous Ampere
Phase	1 Phase
Frequency Rating	60 Hertz
Size	10.25L x 9.688W x 80H
Number Of Cutouts	1
Cutout Size	One 100 Ampere Main Breaker
Cable Entry	Underground
Terminal	Double Mechanical

Insulation	Glass Polyester
Mounting	Pedestal
Enclosure	G90 Galvanized Steel with Powder Coat Finish
Jaw Quantity	4 Terminal
Bypass Type	No Bypass
Number of Meter Positions	Single Power Head
Equipment Ground	Ground Bar
Hub Opening	Plain Top
Line Side Wire Range	6 AWG - 350 kcmil
Load Side Wire Range	1 - 3 AWG
Number Branch Circuits	4
Number Of Receptacles	0

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.



FEATURE TABLE		
ITEM	QTY	DESCRIPTION
A	4	STD. MNTG. EMBOSS
B	2	1/4 SOLID K.O.
C	2	1/2, 3/4 CONC. K.O.
D	3	1, 1 1/4, 1 1/2, 2 CONC. K.O.
E	1	WESTERN LIGHT OPENING



MILBANK
ENERGY AT WORK

Version:

1

**All dimensions are +/- 1/16".
Drawing views are not to scale.**

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility, and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.




U5240-O-100S




Catalog Number	U5240-O-100S
Marketing Product Description	4 Terminal Ring Type Plain Top 1-100 Ampere Main Breaker Single Pedestal Direct Bury Series Wired
UPC	784572287709
Length (IN)	10.25
Width (IN)	9.688
Height (IN)	80
Brand Name	Milbank
Type	Ring Type Meter Socket
Special Features	Florida Meter Group
Application	Mobile Home Power
Standard	UL Listed;Type 3R
Voltage Rating	Up to 240 Volts Alternating Current
Amperage Rating	200 Continuous Ampere
Phase	1 Phase
Frequency Rating	60 Hertz
Size	10.25L x 9.688W x 80H
Number Of Cutouts	1
Cutout Size	One 100 Ampere Main Breaker
Cable Entry	Underground
Terminal	Double Mechanical

Insulation	Glass Polyester
Mounting	Pedestal
Enclosure	G90 Galvanized Steel with Powder Coat Finish
Jaw Quantity	4 Terminal
Bypass Type	No Bypass
Number of Meter Positions	Single Power Head
Equipment Ground	Ground Bar
Hub Opening	Plain Top
Line Side Wire Range	6 AWG - 350 kcmil
Load Side Wire Range	1 - 3 AWG
Number Branch Circuits	4
Number Of Receptacles	0

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.



FEATURE TABLE		
ITEM	QTY	DESCRIPTION
A	4	STD. MNTG. EMBOSS
B	2	1/4 SOLID K.O.
C	2	1/2, 3/4 CONC. K.O.
D	3	1, 1 1/4, 1 1/2, 2 CONC. K.O.
E	1	WESTERN LIGHT OPENING



MILBANK
ENERGY AT WORK

Version:

1

**All dimensions are +/- 1/16".
Drawing views are not to scale.**

Please consult serving utility for their requirements prior to ordering or installing, as specifications and approvals vary by utility, and may require local electrical inspector approval. All installations must be installed by a licensed electrician and must comply with all national and local codes, laws and regulations. Milbank reserves the right to make changes in specifications and features shown without notice or obligation.